



Investing in our Water System Planning for the Next 20 Years




Table of Contents

- A History of Reliable Service
- The Master Planning Process
- About the Water Treatment Plant
- Regional Growth Projections
- Treatment Expansion Alternatives and Recommendations
- Condition Assessment and Recommendations
- Hydraulic Assessment and Recommendations
- Next Steps

BISMARCK
WATERWORKS



A History of Reliable Water Service



Over the past 100 years the City has maintained and updated the original plant to support growth and economic development in the region.



Master Plan Drivers

Reliability

Process equipment, structural, electrical, mechanical, health & safety, age and condition of facilities



Growth

Population growth and peak day water demands



Water Quality/Regulatory

Water hardness goals, Contaminants of emerging concern



The Master Planning Process



Review plant condition



Identify rehab needs including immediate improvements



Evaluate processes to meet future capacity and water quality needs



Recommend schedule for improvements and plant expansion




Estimate costs




Bismarck's Water Treatment Plant

- Treats up to 28 MGD of Missouri River Water through collector wells and surface water intake.
- Original plant built in 1920's
- Major expansion or refurbishment done in 1950's, 1970's, 1990's and 2010's.
- The last Master Plan was completed in 1998.


Estimated
Population in 1965:
31,200



Estimated
Population in 2020:
81,000




Bismarck Growth through 2040



* Does not include Lincoln or South Central Regional Water District service population

Water Use Predictions



- Water use is expected to increase with population growth
- Existing plant can treat up to 28 million gallons per day (MGD)
- Future design capacity of 40 MGD to meet peak day demands through 2040
- Timing for plant expansion will depend on monitoring of water use trends

Water Treatment Plant Expansion

- Three alternative processes evaluated.



Alternative 1: Lime Softening & Media Filtration




Alternative 2: Ultrafiltration & Membrane Softening




Alternative 3: Lime Softening & Ultrafiltration

- All processes considered would meet projected demands and water quality goals.


Current Water Treatment Process




Alternative 1 – Lime Softening and Media Filtration




Alternative 2 – Ultrafiltration and Membrane Softening



Alternative 3 – Lime Softening and Ultrafiltration




Capital Costs Evaluation



Comparing Capital Cost with Non-Monetary Score

- Monetary evaluation included capital cost and total of operation and maintenance costs over 20 years.
- Non-monetary evaluation conducted by staff to assess **operational flexibility, availability of chemicals, makes use of existing facilities, etc.**

Life Cycle Evaluation



Comparing 20-year Net Present Value with Non-Monetary Score

- Monetary evaluation included capital cost and total of operation and maintenance costs over 20 years.
- Non-monetary evaluation conducted by staff to assess **operational flexibility, availability of chemicals, makes use of existing facilities, etc.**

Best Alternative – Alternative 2

| Item | Cost |
|--|----------------------|
| Construction Cost | \$63,000,000 |
| Annual O&M Costs | \$4,700,000 |
| 20-Year NPV O&M (2.5%) | \$73,000,000 |
| Total NPV (Total Capital + NPV O&M) | \$136,000,000 |

Ultrafiltration & Membrane Softening is the best-value alternative

Condition Assessment and Recommendations



- Nearly \$17 Million in rehabilitation and replacement projects recommended in next 8 to 10 years
- Improvements will improve reliability of the existing processes and maintain existing facilities in good condition.
- Improvement types: Piping upgrades, SCADA upgrades, replace chemical feed equipment, pump motors and VFDs, other structural, architectural, mechanical, electrical improvements

VFD Pump Considerations & Other Fix Now Items



- Existing high service pumps are soft starts with one VFD
- Concern with condition/age and reliability
- Address immediately
- Begin improvements to other critical assets

Hydraulic Assessment and Recommendations



- Hydraulics of the existing plant were assessed
- Capacity is limited to 28 MGD because of hydraulic constrictions
- Recommended improvements include upsizing filter piping and re-coating the influent channel to reduce friction
- Short-term investment can increase capacity to approximately 31 MGD

Next Steps

